

LEGEND		** REFER TO THE BELOW ABBREVIATIONS FOR INSTALLATION LEVEL			
SYMBOL	DESCRIPTION	LL	SKIRTING LEVEL	WIFI	WIFI PORT
	MCB BOARD	ML	MIDDLE LEVEL	AC	FAN COIL UNIT
	13A SOCKET OUTLET	HL	HIGH LEVEL		
	13A TWINS SOCKET OUTLET	CM	CEILING MOUNTED		
	13A TWINS SOCKET OUTLET WITH TYPE C USB CHARGE PORT	FM	FLOOR MOUNTED		
	DATA / VOICE OUTLET POINT	FB	FLOOR BOX		
	20A CONNECTION UNIT	BL	BENCH LEVEL		
	32A COOKER SWITCH	TM	TABLE MOUNTED		
	13A FUSE SPUR UNIT				
	JUNCTION BOX CONNECT TO POWER TRUNK				
	POWER MODULE (2NOS. 13A SOCKET, 1 NO. TYPE A & 1 NO. TYPE C USB CHARGE PORT)				
	POWER EXTENSION CORD (4NOS. 13A SOCKET, 4NOS. USB CHARGE PORT)				
	MOBILE POWER KIT (FIVE MOBILE POWER UNITS AND ONE CHARGING TRAY)				

REMARKS

1. ONE CIRCUIT MAXIMUM CAN ONLY BE CONNECTED TO 6 NO. WORKSTATION
2. THE CIRCUIT FOR WORKSTATION CANNOT BE CONNECTED TO CLEANING SOCKET.
3. POWER SOCKET FOR EACH SERVER RACK SHOULD BE CONNECTED TO INDEPENDENT CIRCUIT.
4. NUMBERS OF 13A FUSE SPUR UNIT FOR FAN COIL UNIT, PLEASE REFER TO THE NUMBERS OF FAN COIL UNIT SHOWN ON THE MVAC SERVICE PLAN
5. THE CONTRACTOR IS REQUIRED TO VERIFY THE ACTUAL LOCTION & ROUTE OF ALL MEP RELATED SERVICES ON SITE. ANY DISCREPANCY FOUND BETWEEN THE DRAWINGS AND ACTUAL SITE CONDITIONS MUST BE SUBMITTED FOR APPROVAL PRIOR TO COMMENCEMENT OF WORK. ANY CLAIMS ON WORK DONE WITHOUT PRIOR APPROVAL WILL NOT BE ACCEPTED AND AT THE CONTRACTOR'S OWN RISK.

